

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1574:103 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Fairfield, NJ 07004-1561
Contact: *Ron Dalton (310) 725-2972 Fax (310) 725-2942

DESIGN: Model ADTG1M and ADTG1M-RM sync modules. Units are an electronic circuit mounted on a printed wiring board and enclosed in a plastic case. Units are intended for use with listee's Model ADTG1 series (CSFM Listing No. 7125-1574:102) and Models ADTG1 and ADTG1R horns and horn strobes (CSFM Listing No. 7125-1574:104). Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as sync module for use with separately listed compatible fire alarm control units. For indoor use only.

XLF: 7125-1591:201 Formerly 7300-1388:230

*Rev. 07-01-2003 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JULY 1, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager